5R Systems.

ENGINEERING TEST RECORD

SAMPLE / DEMO ONLY
Not an official record

Weekly Sprinkler Test

Illustrative signed test evidence - B3 sprinkler room

PASS / SIGNED

SYSTEM	Sprinkler weekly test
LOCATION	B3 sprinkler room
ENGINEER	Demo Engineer
SHIFT	Yellow shift
TEST DATE	11 Nov 2026

REFERENCE: DEMO-SPK-001

TEST TIMELINE

STARTED	COMPLETED	SIGNED & SAVED
09:42	10:09	10:09

RECORDED CHECKS

6 PASSED / 0 FAILED

CHECK / OBSERVATION	TIME	RESULT
Fire Control Centre presence confirmed	09:42	PASS
Pump isolation confirmed before jockey testing	09:50	PASS
Jockey pump activation observed	09:56	PASS
Test valve operation and reset confirmed	10:03	PASS
Main pump power and normal state restored	10:07	PASS
Final area and status check completed	10:09	PASS

ENGINEER SIGN-OFF

Demo Engineer - demonstration sign-off only

Saved 10:09

Illustrative marketing example only. No live test or statutory certification is represented.
5R Systems | Sample test record | For demonstration purposes